



CWDBH will accept equivalent therma-coil pit setters from Ford and AY Macdonald.

250CS1566FABS000741N



1 Lid must come with 2" pre-punched hole for meter reading electronics. Composite or Metal is acceptable.

72.00




DETAIL A

SEE DETAIL A

3/4" NPT INLET AND OUTLET

ITEM NO	DESCRIPTION
1	15" COMPOSITE OR METAL SIDE LOCKING LID
2	15-10 ABS PLATFORM
3	3/4" HOSE CONNECTOR
4	3/4" COIL PART
5	3/4" NIPPLE WITH WRENCH FLATS
6	SHELL SUB ASSEMBLY
7	3/4" HEX NUT
8	15" INSULATION PAD (REQUIRED)
9	3/4" FULL PORT BALL VALVE
10	3/4" METER COUPLING (CODE 250 FOR 9" LAY LENGTH OF 3/4" METER)
11	3/4" INLINE CHECK VALVE



DR. BY						C.B. NO.
CHKR						
ENGR						PATT. NO.
MGR						
MFG						
TOOL						
FDRY						
MATL:						
DESCR. 3/4" COIL SINGLE METER PIT 15" DIA X 72" DEPTH LOW LEAD BRASS						NUMBER